



LAKE HAVASU CITY, ARIZONA
ADMINISTRATIVE SERVICES DEPARTMENT
◆ PROCUREMENT ◆

ITB
8" Force Main Repairs
Project No. SS3030
ADDENDUM NO. 1
March 19th, 2021

Attention is called to the following changes, additions, clarifications and/or deletions to the original solicitation and they shall be taken into account in preparing submissions:

There is no change in the opening date. **Submissions are due no later than 3:00 p.m., Arizona Time, March 24th, 2021** at the City Clerk's Office, 2330 McCulloch Blvd. N., Lake Havasu City, AZ 86403.

There is no change in the opening time. **Submissions are due no later than 3:00 p.m., Arizona Time,** at the City Clerk's Office, 2330 McCulloch Blvd. N., Lake Havasu City, AZ 86403.

ITEM	ACTION	DESCRIPTION or ISSUE
1	Clarification	Is there any color requirement for the 8" & 6" C-900 DR-14 pipe? Standard blue color of said pipe is blue. -Standard blue color is fine.
2	Clarification	In the specs, it says fittings are to be cement line and tar coated, being a sewer force main, should the ductile fittings be P401 lined? -Yes we'd like the fittings to be P401 lined.
3	Clarification	Are the ductile fittings to be "restrained" to the pipe or is this not a requirement for this project? - All fitting to be restrained.

DATE: 03/19/2021

BY: *Shannon Blakey*
Management Analyst