



## LAKE HAVASU CITY, ARIZONA

### ADDENDUM NO. 1

North Well Field Pump and Downhole Improvement Project  
Project 108032

**DATED: JUNE 21, 2023**

This addendum no. 1 forms a part of the contract described above.

**Item No. 1:**

The following questions were received from bidders. Answers are provided herein by the OWNER:

- 1. Question:** *“When is the work expected to begin?”*  
**Answer:** It is anticipated the work will begin mid to end of October.
- 2. Question:** *“Are the allotted 90 Calendar Days per each well?”*  
**Answer:** No. It is for the two base bid wells, wells 10 & 14.
- 3. Question:** *“Does the 90 Calendar Days also include the work on the alternate well 15?”*  
**Answer:** No. If bids come in such that there is available budget to do well 15, additional 45 calendar days will be added for that work.
- 4. Question:** *“Can regular carbon Steel be used as the swedging material?”*  
**Answer:** Yes.
- 5. Question:** *“Do you have video of the hole if well 15 casing?”*  
**Answer:** Yes, and it shows it to be approximately 4” in diameter.
- 6. Question:** *“Will the City perform the Bac-T tests?”*  
**Answer:** Yes.

7. **Question:** *“Are you going to spec out chlorination quantity required?”*  
**Answer:** No. It is to be standard AWWA requirements.
8. **Question:** *“When it comes to discharging the wells will we have to provide the piping and where would we be able to pipe it to?”*  
**Answer:** No. You will be able to use existing underground piping to flush to the wash north of the wells. De-Chlorination will be required.
9. **Question:** *“Will the City accept a sterling product on the well pump?”*  
**Answer:** Yes, if it is equal to the product being specified.
10. **Question:** *“Do we need to bail into a tank?”*  
**Answer:** Yes.
11. **Question:** *“Will the City provide a place to dump the solids?”*  
**Answer:** No. You will need to contain and haul off.
12. **Question:** *“When refurbishing the heads will we need to include a nipple?”*  
**Answer:** No as they should be good.
13. **Question:** *“Can weekly meetings be held via Teams?”*  
**Answer:** Yes.
14. **Question:** *“Can the bids be mailed in as long as they get there before the deadline?”*  
**Answer:** Yes.
15. **Question:** *“Are there working daytime limits?”*  
**Answer:** Yes. City code (9.30.070 B2) allows work on Construction Projects from 5:00 am to 10:00 pm from May 1<sup>st</sup> to September 30<sup>th</sup> and 6:00 am to 10:00 pm October 1<sup>st</sup> to April 30<sup>th</sup>.
16. **Question:** *“Do we need to dispose of materials/equipment removed?”*  
**Answer:** Yes. City would like to salvage equipment that is still operable and of value. This can be evaluated on a case-by-case basis.
17. **Question:** *“Will the electrical panels that appear to be in the way be relocated prior to construction by the City?”*  
**Answer:** No.

18. **Question:** *“Does the engine at Well 15 stay?”*

**Answer:** Yes.

19. **Question:** *“What is the KVA of the power lines running by the wells?”*

**Answer:** City was unable to verify with Unisource. Contractor will need to do so.