



LAKE HAVASU CITY, ARIZONA  
ADMINISTRATIVE SERVICES DEPARTMENT  
◆ PROCUREMENT ◆

**INVITATION TO BID**  
**Fy2025-26 HOT MIX ASPHALT REPAIRS**  
**PROJECT NO. B26-PW-SM604C-500788**  
**ADDENDUM NO. 1**  
**APRIL 8, 2026**

Attention is called to the following changes, additions, clarifications and/or deletions to the original solicitation and they shall be considered in preparing submissions:

There is no change in the opening date. **Submissions are due no later than 3:00 p.m., Arizona Time, April 15, 2026**, at the City Clerk's Office, 2330 McCulloch Blvd. N., Lake Havasu City, AZ 86403.

**ITEM ONE (1): QUESTIONS & ANSWERS**

**Question 1:** *Will the City allow full street closures during construction? Or will we be required to keep at least 1 lane of traffic open at all times?*

**Answer 1:** The City requires that a minimum of one (1) traffic lane be kept open at all times.

**Question 2:** *Proposal states that contractor is responsible for "water disposal". Can this item be eliminated as it would be considered an unforeseen circumstance if water is discovered?*

**Answer 2:** No. If water is encountered, any over-excavation required to achieve proper compaction will be considered incidental to the project.

**Question 3:** *Confirm no builders risk insurance is required on this project as it is not vertical construction.*

**Answer 3:** The project is not vertical construction, therefore, no builders risk insurance is required.

**Question 4:** *Please confirm what testing & inspection will be required for this project that the contractor would be responsible for?*

**Answer 4:** The contractor will be responsible for conducting all required testing and inspection related to the aggregate base (AB) material and the asphalt concrete.

**Question 5:** *Confirm no formal engineered as-builts are required for this project.*

**Answer 5:** No formal engineered as-builts are required.

**Question 6:** *As there is no changes to grades or elevations required in this project, please advise if a surveyor will be required onsite?*

**Answer 6:** Surveyors are not required onsite.

**Question 7:** *Will temp mailboxes be required on this project? Areas should be closed for a maximum of 1 day.*

**Answer 7:** Temporary mailboxes will not be required for this project.

**Question 8:** *Special conditions state that contractor shall provide temporary office facilities. Please confirm no facilities will be required for this project.*

**Answer 8:** No facilities will be required for this project.

**Question 9:** *Will formal traffic control plans be required for this project? And if so, do they need to be stamped?*

**Answer 9:** Yes, a formal traffic control plan is required for each work location.

**Question 10:** *Please confirm no striping is required for this project.*

**Answer 10:** No striping is required for this project.

**Question 11:** *Please confirm if there are any survey monuments that will be disturbed in the work areas?*

**Answer 11:** There may be survey monuments in some of the work areas.

**Question 12:** *It is our understanding that the City is self-performing compaction testing. Please confirm if there is any expense to the contractor for this.*

**Answer 12:** No, the City will not be performing compaction testing for this project. The contractor will be responsible for providing compaction testing for both the aggregate base (AB) material and the asphalt.

*Susie*

**Senior Procurement Specialist**