

ADDENDUM NO. 2

**LAKE HAVASU CITY
LAKE HAVASU CITY MUNICIPAL AIRPORT
APRON REHABILITATE – INFIELD AREAS EROSION CONTROL
(City Project Name: Rehabilitate & Reconstruct Taxiway)
LHC PROJECT No. 104004
ADOT NO. EOS2E01C**

In accordance with the Special Provisions to the General Provisions, SP 20-16, Addenda and Interpretation, the following revisions to the Plans and Specifications shall become a part of the Contract Documents and each bidder shall acknowledge receipt thereof on page PROPOSAL-23 of the Proposal Forms.

GENERAL

- ITEM 1:** The Bid Due Date has been changed to March 9, 2022 at 3:00 p.m., ARIZONA TIME. All references contained in the Contract Documents shall be revised to reflect the new due date.
- ITEM 2:** An optional Site Visit has been scheduled for March 2, 2022 at 11:00 a.m. All questions arising from this site visit shall be submitted in writing and will be answered in addendum.

SPECIFICATIONS

- ITEM 3:** PROPOSAL FORM, page PROPOSAL-2. Delete this page in its entirety and replace it with the revised page included as **Attachment A**.
- ITEM 4:** SPECIAL PROVISIONS TO THE GENERAL PROVISIONS, SP 20-16 Addenda and interpretation. With pen and ink cross out “sent by certified mail with return receipt requested to all holders of Contract Documents at the respective addresses furnished for such purposes,” and replace it with “posted on the City’s website,”
- ITEM 5:** SPECIAL PROVISIONS TO THE GENERAL PROVISIONS, SP 70-23 Federal Contract Provisions for procurement and contracting under AIP. Delete this section in its entirety.
- ITEM 6:** TECHNICAL PROVISIONS, page TS-P-218-2, 218-3.3. First paragraph, with pen and ink cross out the word “sterilized”.

QUESTIONS

- ITEM 7:** Questions about how excavation of existing millings is paid.
Answer – The excavation of the existing millings is paid for under P-152 EXCAVATION AND EMBANKMENT.
- ITEM 8:** Questions about leaving open excavations adjacent to the edge of the Runway and Taxiways.
Answer – All excavations within the RSA or TSA must be backfilled or have P-218 placed within the same work shift prior to opening to aircraft traffic. Refer to the CSPP for grading requirements of the RSA and TSA while open to aircraft.

ITEM 9: Question: Can the excavated material be stockpiled in the staging area at night, and then hauled away during the day?

Answer – Yes, all work impacting aircraft movement areas, including Runway, Taxiways, and Aprons must be completed during night time closures in accordance with the CSPP. Material stockpiled in accordance with the CSPP outside of these areas may be hauled from the project site during daytime hours provided that the areas described above are not impacted by the hauling operations.

ITEM 10: Question: Is there a hydrant or other water source available on site?

Answer – Yes, Water hydrants are available in site, the contractor is responsible for obtaining a water meter from the City Water Department.

ITEM 11: Question: What are the Covid requirements for this project?

Answer – Project Covid requirements are in accordance with Federal, State and City requirements.

Attachment A

ITEM NO.	FAA SPEC NO.	QUANTITY	ITEM LIST ITEM DESCRIPTION (PRICE WRITTEN IN WORD)		UNIT PRICE IN FIGURES		TOTAL AMOUNT	
					DOLLARS	CENTS	DOLLARS	CENTS
BASE BID								
1	P-156	1 LS	TEMPORARY AIR AND WATER POLLUTION, SOIL EROSION, AND SILTATION CONTROL AT					
			PER LUMP SUM					
2	GP-105	1 LS	MOBILIZATION AT					
			PER LUMP SUM					
3	M-100	1 LS	SAFETY, SECURITY AND MAINTENANCE OF TRAFFIC AT					
			PER LUMP SUM					
4	M-150	1 LS	PROJECT SURVEY & STAKEOUT AT					
			PER LUMP SUM					
5	P-152	600 CY	EXCAVATION AND EMBANKMENT AT					
			PER CUBIC YARD					
6	P-218	27,700 SY	4" CRUSHED AGGREGATE EROSION CONTROL & SLOPE PROTECTION AT					
			PER SQUARE YARD					
BID ALTERNATE 1								
7	P-218	10,000 SY	4" CRUSHED AGGREGATE EROSION CONTROL & SLOPE PROTECTION AT					
			PER SQUARE YARD					
8	P-152	120 CY	EXCAVATION AND EMBANKMENT AT					
			PER CUBIC YARD					
TOTAL PRICE (WRITTEN IN WORD) - BASE BID							DOLLARS	CENTS
TOTAL PRICE (WRITTEN IN WORD) - BID ALTERNATE NO. 1							DOLLARS	CENTS