



**LAKE HAVASU CITY**  
**Administrative Services**

**PROCUREMENT DIVISION**

**INVITATION TO BID**  
**NRP CHAIN & RAKE BAR SCREEN SYSTEM & WASHFACTOR**  
**REPLACEMENT**  
**PROJECT NO. ITB B21-WWTP-500088**  
**ADDENDUM NO. 2**  
**DATE: SEPTEMBER 24, 2020**

Attention is called to the following changes, additions, clarifications and/or deletions to the original solicitation and they shall be taken into account in preparing submissions:

There is no change in the opening date. **Submissions are due no later than 3:00 p.m., Arizona Time, SEPTEMBER 30, 2020**, at the City Clerk's Office, 2330 McCulloch Blvd. N., Lake Havasu City, AZ 86403.

<b>ITEM</b>	<b>DESCRIPTION or ISSUE</b>
<b>Substitution Request:</b>	Substitution Request Pre-Submittal from OR-TEC, Inc. Blue Whale Micro Bar <a href="https://www.or-tec.com/micro-bar-screen">https://www.or-tec.com/micro-bar-screen</a>
<b>Substitution Answer:</b>	Substitution request accepted for bid consideration. The proposed equipment must fit inside the current channel with no modifications, meet flow demands of 14 MGD, and have 3mm screen openings.

DATE: 9/24/2020

BY: Lynette Singleton  
Lynette Singleton, Procurement Official